August 12, 2014 S/T File: C14000, C14001 (Final Certification)

Keith Speak Plant Manager Desert View Power, Inc. 62-300 Gene Welmas Drive Mecca, CA 92254

(CEMS Modification - Correction)

Subject:

Final Certification of Non-RECLAIM CEMS:

Boiler No. 1 Boiler No. 2

Dear Mr. Speak:

I have completed the evaluation of your CEMS (Continuous Emissions Monitoring System) certification report for the Desert View Power, Inc. Boiler No. 1 and Boiler No. 2. This evaluation was made to determine if certification could be granted based on having complied with all the monitoring, reporting, and recordkeeping requirements of the applicable protocols found in <u>District Rules 218 and 218.1.</u>

This letter serves as an official notification of final certification for the CEMS, and all the associated mechanical and electronic components (excluding the RTU) at your facility serving the devices described in the accompanying attachment, "REGULATION XX RECLAIM, EPA Acid Rain, and NON-RECLAIM CEMS FINAL CERTIFICATION: Specific Device-Based Information and Conditions". If the CEMS information in the accompanying attachments is not accurate, please notify me as soon as possible at (909) 396-2244. Also, please remember to notify the District for direction, prior to replacement or modification of the described CEMS or the device(s) that it serves, since such modifications may change the compliance status of the affected CEMS. Again, thank you for your continued cooperation and support.

We appreciate the diligent and cooperative efforts you have shown in support of RECLAIM (Regional Clean Air Incentive Market) Regulation XX, Rules 218 and 218.1 and 40 CFR 75 concerning the implementation of the CEMS (Continuous Emissions Monitoring System) program at the Desert View Power, Inc.

Sincerely,

Muhael A. Lewoni
Michael A. Cecconi, Senior Air Quality Engineer

Source Test Engineering

Attachment

cc: David Jones

Page 2

August 12, 2014

Device I.D.:

N/A

C14000, C14001 Source Test I.D.:

SOUTH COAST AIR QUALITY MANAGEMANT DISTRICT

NON-RECLAIM CEMS FINAL CERTIFICATION:

Specific Device-Based Information and Conditions

(This document must be displayed on or near strip chart recorder)

Name of Facility:

Desert View Power, Inc.

Certification Test Date:

April 8, 2014 (for NOx at Boiler No. 1) April 8, 2014 (for SO₂ at Boiler No. 1) April 8, 2014 (for CO at Boiler No. 1) April 8, 2014 (for NOx at Boiler No. 2) April 8, 2014 (for SO₂ at Boiler No. 2) April 8, 2014 (for CO at Boiler No. 2) June 28, 1994 (for opacity at Boiler No. 1)

Effective Date for Valid Data:

April 8, 2014 (for NOx at Boiler No. 1) April 8, 2014 (for SO_2 at Boiler No. 1) April 8, 2014 (for CO at Boiler No. 1) April 8, 2014 (for NOx at Boiler No. 2) April 8, 2014 (for SO₂ at Boiler No. 2) April 8, 2014 (for CO at Boiler No. 2) June 28, 1994 (for opacity at Boiler No. 2)

Equipment Description:

Boiler No. 1 Boiler No. 2

Mailing Address:

62-300 Gene Welmas Drive

Mecca, CA 92254

Equipment Location:

62-300 Gene Welmas Dr., Mecca, CA 92254

A. The components described below comprise the "CEMS" which has been granted Final Certification or Approval and they may not be changed or modified without prior District (Unauthorized modification to the components shown below may void CEMS certification, and result in non-compliance with District RECLAIM Rules 2011 & 2012. Be sure the information below is correct. Contact your District Source Testing representative if there are any questions):

Boiler No. 1

Gaseous Emission Measurement Analyzer

Gaseous Component Monitored	Manufacturer	Model No.	Serial No.	Method of Detection	Certified Range(s)
NOx	California Analytical Instruments	ZRE- C2COS2NOO2P	A3F4992T	Non-Dispersive Infrared (NDIR) with an external vitreous carbon NO ₂ -to-NO converter	0-100 ppm 0-500 ppm
SO ₂	California Analytical Instruments	ZRE- C2COS2NOO2P	A3F4992T	Non-Dispersive Infrared (NDIR)	0-50 ppm 0-500ppm
СО	California Analytical Instruments	ZRE- C2COS2NOO2P	A3F4992T	Non-Dispersive Infrared (NDIR)	0-10 ppm 0-2000 ppm

Page 3

Facility I.D.:

100154 Device I.D.: N/A

Source Test I.D.:

C14000, C14001

Gaseous Component Monitored	Manufacturer	Model No.	Serial No.	Method of Detection	Certified Range(s)
CO ₂	California Analytical Instruments	ZRE- C2COS2NOO2P	A3F4992T	Non-Dispersive Infrared (NDIR)	0-20 %
Dry O ₂	California Analytical Instruments	ZRE- C2COS2NOO2P	A3F4992T	Paramagnetic	0-25 %
Wet O ₂	Thermox	WDG-Series 2000	10212255-3	Zirconium Oxide Cell	0-25 %
Opacity	Monitor Labs	Lighthawk 560	5600142	Dual-Pass	0-100%

Fuel or Flue Gas Flow Measurement Analyzer

1 401 01 1140 04	Instrument Type	Manufacturer	Model No.	Serial No.
Annubar Stack F	low Monitor (0-20,000 DSCFH)	Dieterich Standard	70	N/A

Supporting Equipment (Data Acquisition, Reduction, and Recording) Excluding RTU

Type	Manufacturer	Model No.	Serial No.
DAHS Computer	Allen Bradley	Panel View Plus 600	N/A
PLC	Allen Bradley	Compact Logix	N/A
PLC Data Control Unit	Allen Bradley	Compact Logix	N/A
Electronic Data Recorder Software Package	Dell	CeDar	N/A
Electronic Data Recorder	Dell	Optiplex 980	N/A

DAS, PLC Programming Formulas and Correction Factors

Parameter	Formula	
NOx Concentration	as specified in CEMS application	
SO ₂ Concentration	as specified in CEMS application	
CO Concentration	as specified in CEMS application	
CO ₂ Concentration	as specified in CEMS application	
O ₂ Concentration	as specified in CEMS application	
Stack Flow Rate*	as specified in CEMS application*	
NOx Emission Rate	as specified in CEMS application	
SO ₂ Emission Rate	as specified in CEMS application	
CO Emission Rate	as specified in CEMS application	

Boiler No. 2

Gaseous Emission Measurement Analyzer:

Gaseous Component Monitored	Manufacturer	Model No.	Serial No.	Method of Detection	Certified Range(s)
NOx	California Analytical Instruments	ZRE- C2COS2NOO2P	A3F4993T	Non-Dispersive Infrared (NDIR) with an external vitreous carbon NO ₂ -to-NO converter	0-100 ppm 0-500 ppm

Facility I.D.:

100154

Page 4

August 12, 2014

Device I.D.:

N/A

Source Test I.D.:

C14000, C14001

Manufacturer Model No. Serial No. Method of Detection Certified Gaseous Component Range(s) Monitored 0-50 ppm A3F4993T Non-Dispersive Infrared SO_2 California ZRE-C2COS2NOO2P 0-500ppm Analytical (NDIR) Instruments COCalifornia ZRE-A3F4993T Non-Dispersive Infrared 0-10 ppm 0-2000 ppm Analytical C2COS2NOO2P (NDIR) Instruments $\mathbb{C}\mathbb{O}_2$ ZRE-A3F4993T Non-Dispersive Infrared California 0-20 % Analytical C2COS2NOO2P (NDIR) Instruments Dry O2 California ZRE-A3F4993T Paramagnetic 0-25 % Analytical C2COS2NOO2P Instruments Wet O₂ Thermox WDG-Series 2000 10212255-1 Zirconium Oxide Cell 0-25 % Monitor Lighthawk 560 5600142 **Dual-Pass** 0-100% Opacity

Fuel or Flue Gas Flow Measurement Analyzer

Labs

Instrument Type	Manufacturer	Model No.	Serial No.
Annubar Stack Flow Monitor (0-20,000 DSCFH)	Dieterich Standard	70	N/A

Supporting Equipment (Data Acquisition, Reduction, and Recording) Excluding RTU

Туре	Manufacturer	Model No.	Serial No.
DAHS Computer	Allen Bradley	Panel View Plus 600	N/A
PLC	Allen Bradley	Compact Logix	N/A
PLC Data Control Unit	Allen Bradley	Compact Logix	N/A
Electronic Data Recorder Software Package	Dell	CeDar	N/A
Electronic Data Recorder	Dell	Optiplex 980	N/A

DAS, PLC Programming Formulas and Correction Factors

Parameter	Formula		
NOx Concentration	as specified in CEMS application		
SO ₂ Concentration	as specified in CEMS application		
CO Concentration	as specified in CEMS application		
CO ₂ Concentration	as specified in CEMS application		
O ₂ Concentration	as specified in CEMS application		
Stack Flow Rate*	as specified in CEMS application*		
NOx Emission Rate	as specified in CEMS application		
SO ₂ Emission Rate	as specified in CEMS application		
CO Emission Rate	as specified in CEMS application		

B. The CEMS described above is subject to the following conditions:

 A new RATA test protocol must be submitted for District approval if RATA procedures differ from the previously approved CEMS certification test protocol. Facility I.D.:

100154

Page 5

Device I.D.:

N/A

Source Test I.D.:

C14000, C14001

• A schedule of RATAs for each calendar quarter must be provided at least two weeks prior to the beginning of each calendar quarter.

August 12, 2014

- The daily instrument calibration error check shall be performed by injecting calibration gases at the sample probe.
- The CEMS sample conditioning system shall achieve moisture and particulate removal without altering the concentration of the monitored gaseous contaminants. The monitored gaseous constituents exiting the sample conditioning system shall be maintained at or below a dew point of 37°F.
- The modified CEMS for Boilers 1 and 2 at Desert View Power, Inc. are considered to be modified CEMS for the purposes of compliance with Rules 218 and 218.1. Modified CEMS have different requirements from the existing CEMS under Rules 218 and 218.1 and must comply with the same set of requirements as new CEMS as defined by Rules 218 and 218.1. CEMS modified after May 14, 1999 are considered modified CEMS and shall be maintained and operated according to the provisions of Rule 218, Sections (b), (c), (e), (f) and (g), and the requirements of Rule 218.1, Sections (b) and (d).

If any aspect of your CEMS QA/QC is changed in the future, the QAP shall be updated and the updated portions submitted to the District within 15 days of the change. However, no QA/QC tasks shall be removed from the approved QAP without District review and approval. QA/QC tasks, in addition to the approved plan may be implemented at once with proper documentation.

Evaluated By:

Michael A. Cecconi, Senior Air Quality Engineer

Source Test Engineering

South Coast Air Quality Management District

2244

mcecconi@aqmd.gov

Desert View Power



South Coast Air Quality Management District

Headquarters 21865 Copley Drive Diamond Bar CA 91765-4178

FORWARDING SERVICE REQUESTED

Printed on Recycled Paper.







Attn: Keith Speak Plant Mgr. Desert View Power, Inc. 62-300 Gene Welmas Dr. Mecca, CA 92254

روي معمد بردون بردون و اول ه بردود؟ حري دوي و اولوه ه در ومدد وحوزه دوي دوي _ Ուլիինովուն կոնիների իրկանի դուներինին ներկանի և իրկան